

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Sri Guru Harkrishan Public School Basant Avenue, Amritsar
Sri Guru Harkrishan Public School (CKDCS) Basant Avenue, Amritsar


No.: RWTLASR/2526/01012 Dated : 01/11/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 2025-26 Dated: 29/10/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 31/10/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

INVOICE

Bill No. : INV/2526/01014

Date. : 31/10/2025

To,

Principal Sri Guru Harkrishan Public School Basant Avenue, Amritsar
Sri Guru Harkrishan Public School (CKDCS) Basant Avenue, Amritsar

Ref. : Letter No. 2025-26 Dt. 29/10/2025

Sample Receiving No. RWTLASR/R2526/01014 Dt. 31/10/2025

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Basant Avenue (S/pump 300 ft)	Water	Private Schools	Basic Chemical : Colour, Turbidity, Total Alkalinity, pH, Odour, Taste, TDS, Chloride, Magnesium, Calcium, Total Hardness	1	156.00	156.00
Total							156.00

One Hundred Fifty Six Only.

Payment Mode : Cash

Payment Status : PAID

STR No. : 2025-26 29/10/2025

Note:- * Discount applicable as per Government Notification Number : 987 & Date : 23/05/2025


Mr. Nitin Kalia
Authorised Signatory

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com



TC-13602

TEST REPORT

Name & Address of Customer : Principal Sri Guru Harkrishan Public School Basant Avenue, Amritsar Sri Guru Harkrishan Public School (CKDCS) Basant Avenue, Amritsar		Customer Reference No.	No : 2025-26 Dated : 29/10/2025
		Sample Submitted by	Mr. Anmol Singh
		Date of Sample Receipt	31/10/2025
		Analysis Starting Date	31/10/2025
		Analysis completion Date	01/11/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC13602250000899F	Sample Type :	Water
Test Report No.:	RWTLASR/2526/01012	Date of Issue :	01/11/2025
Registration no.:	RWTLASR/REG2526/06278	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Basant Avenue(S ₇ pump 300 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.58@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	371	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.75@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO ₃)	296	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO ₃)	264	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	52.90	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	32.07	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	49.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Amritsar

----- End of the Test Report -----